

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No. CMO-1654

Date : 07-02-2025

It is certified that an inspection team headed by Dr S.K. Rahul (Name of Officers with designation) from Dcmo Office Of the Chief Medical Officer Agra (Name of Department/Office) inspected the **POOJA PUBLIC SCHOOL , GOPAL PURA MOD BHADRAULI BAH AGRA UP** (Name & Address of the School) on **30.01.2025** and found that the **POOJA PUBLIC SCHOOL , GOPAL PURA MOD BHADRAULI BAH AGRA UP** (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/ U. TGovt.

The above valid for a period of 31.03.2025.

Signature with Seal:

मुख्य चिकित्सा अधिकारी
आगरा

07/02/25

Name :

Designation :

To

**POOJA PUBLIC SCHOOL ,
GOPAL PURA MOD BHADRAULI BAH AGRA**

JALKAL LABORATORY (HQ), NAGAR NIGAM, AGRA

Chemical Water Analysis Test Report

Source of Sample — Submersible

Agency/Deptt.-Pooja Public School, Gopal Pura Mod,Bhadrauli, Bah, Agra-283113

Date and Time of Collection: 27-12-2024 (8.30 am) Date of Receipt 27-12-2024 (12.30 pm)

Sr. No	Parameters	IS : 10500(2012)	Result	Unit
1	Turbidity	1.0-5.0	0.2	NTU/1
2	Colour	5.0-15.0	NIL	P.Scale
3	pH	6.5-8.5	7.37	-
4	Total Dissolved Solids (TDS)	500.2-2000.0	730	Mg/L
5	Total Hardness as CaCO ₃	200-600	210	Mg/L
6	Calcium Hardness	-	110	Mg/L
7	Magnesium Hardness	-	100	Mg/L
8	Total Alkalinity (M) as CaCO ₃	200.0-600.0	240	Mg/L
9	Chlorides	250.-1000	260	Mg/L
10	Sulphate	200-400	205	Mg/L
11	Nitrates	45-100	NIL	Mg/L
12	Flourides	1.0-1.2	1.0	Mg/L
13	Calcium as Ca ⁺⁺	75.0-200.2	44.0	Mg/L
14	Magnicium as Mg ⁺⁺	30.0-100	24.4	Mg/L
15	Iron as Fe	0.30-1.0	0.50	Mg/L
16	Maganese	0.1-0.3	0.30	Mg/L
17	Ammonia	0.1-0.5	NIL	Mg/L

Bacteriological Test Report

			Result	
1	Coliform	NIL	NIL	CFU/100 MI
2	E.Coli	NIL	NIL	CFU/100 MI

Remark:- The result conforms to standard IS : 10500 (2012) hence potable.

[Signature]
Chief Chemist
Jalkal Sansthan, Agra

Chief Chemist

Jalkal Vibhag, Nagar Nigam, Agra