

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. C.M.O./14

Dated: 05-05-2026



It is certified that an inspection team headed by **Dr. Anshul Pareek**

(Name of Officers with designation) from **Dy CMO PHED** inspected the **Pooja Public School Gopal Pura Mod, Bhadrauli, Bah, Agra.**

(Name & Address of the school) on **04-05-2026** (date of inspection) and on the basis of Water Test Report (Attached) bearing no **Chemical Water Analysis Test Report Jalkal Vibhag, Agra** dated **01-04-2026** of **Jalkal Vibhag Agra** (PHED Lab) certified that the

Pooja Public School Gopal Pura Mod, Bhadrauli, Bah, Agra. (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till **31st March, 2027**

Signature with Seal:  
Name : **Dr. Anshul Pareek**
Designation : **Dy. CMO**
Name & Address of the Office / Department:
Office Chief Medical officer near Central Jail road, Agra.

To

Pooja Public School Gopal Pura Mod, Bhadrauli, Bah, Agra.

(Name & Address of the Institution)



CHEMICAL WATER ANALYSIS TEST REPORT

Source of Sample:- Submersible

Agency/Deptt.:- Pooja Public School, Gopal Pura Mod, Bhadrauli, Bah Agra-
(UP)-283113

Date And Time of Collection:- 01.04.2026 (9:15 AM)

Date And Time of Receipt:- 01.04.2026 (01:30 PM)


S.No.	Parameters	IS : 10500(2012)	Result	Unit
1	Turbidity	1.0-5.0	0.3	NTU/l
2	Colour	5.0-15.0	NIL	P.Scale
3	pH	6.5-8.5	7.39	-
4	Total Dissolved Solids (TDS)	500.2-2000.0	810	Mg/L
5	Total Hardness as CaCo ₃	200-600	130	Mg/L
6	Calcium Hardness	-	120	Mg/L
7	Magnesium Hardness	-	110	Mg/L
8	Total Alkalinity (M) as CaCo ₃	200.0-600.0	234	Mg/L
9	Chlorides	250.1000	254	Mg/L
10	Sulphate	200-400	198	Mg/L
11	Nitrates	45-100	NIL	Mg/L
12	Flourides	1.0-1.5	0.8	Mg/L
13	Calcium as Ca ⁺⁺	75.0-200.2	48	Mg/L
14	Magnicium as Mg ⁺⁺	30.0-100	26.84	Mg/L
15	Iron as fe	0.30-1.0	0.40	Mg/L
16	Maganese	0.1-0.3	0.20	Mg/L

THE SAMPLE IS COLLECTED AND
DEPOSITED BY THE PARTY ITSELF

Bacteriological Test Report

			Result	
1	Coliform	NIL	NIL	CFU/100 MI
2	E. Coil	NIL	NIL	CFU/100 MI

Remark:- The result conforms to standard IS : 10500 (2012) hence potable.


23/04/26
Chief Chemist
JalKal Vibhag,
Nagar Nigam, Agra