

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 03

Dated: 16/04/25

It is certified that an inspection team headed by Dr. Nandan Singh Dy. C.M.O.

(Name of Officers with designation) from C.M.O. office Agra PHED

inspected the Pooja Public S.R. SEC. School Gopalpura Mod Bhadrauli, Bah, Agra

(Name & Address of the school) on 11.4.25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. Report Attached dated 27.12.2024

of Tal. Kal Laboratory (PHED Lab) certified that the

(H.O) Nagar Nigam Agra (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 31.03.2026

Signature with Seal: उप मुख्य चिकित्सधिकारी

Name: Dr. Nandan Singh

Designation: Dy. C.M.O.

Name & Address of the Office / Department: C.M.O

office Agra

To

Pooja Public S.R. SEC. School Gopalpura Mod Bhadrauli, Bah, Agra
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

JALKAL LABORATORY (HQ), NAGAR NIGAM, AGRA

Chemical Water Analysis Test Report

Source of Sample — Submersible

Agency/Deptt.-Pooja Public School, Gopal Pura Mod,Bhadrauli, Bah, Agra-283113


Date and Time of Collection: 27-12-2024 (8.30 am) Date of Receipt 27-12-2024 (12.30 pm)

Sr. No	Parameters	IS : 10500(2012)	Result	Unit
1	Turbidity	1.0-5.0	0.2	NTU/l
2	Colour	5.0-15.0	NIL	P.Scale
3	pH	6.5-8.5	7.37	-
4	Total Dissolved Solids (TDS)	500.2-2000.0	730	Mg/L
5	Total Hardness as CaCO ₃	200-600	210	Mg/L
6	Calcium Hardness	-	110	Mg/L
7	Magnesium Hardness	-	100	Mg/L
8	Total Alkalinity (M) as CaCO ₃	200.0-600.0	240	Mg/L
9	Chlorides	250.-1000	260	Mg/L
10	Sulphate	200-400	205	Mg/L
11	Nitrates	45-100	NIL	Mg/L
12	Flourides	1.0-1.2	1.0	Mg/L
13	Calcium as Ca ⁺⁺	75.0-200.2	44.0	Mg/L
14	Magnesium as Mg ⁺⁺	30.0-100	24.4	Mg/L
15	Iron as Fe	0.30-1.0	0.50	Mg/L
16	Manganese	0.1-0.3	0.30	Mg/L
17	Ammonia	0.1-0.5	NIL	Mg/L

Bacteriological Test Report

			Result	
1	Coliform	NIL	NIL	CFU/100 MI
2	E.Coli	NIL	NIL	CFU/100 MI

Remark:- The result conforms to standard IS : 10500 (2012) hence potable.


Chief Chemist
Jalkal Vibhag, Nagar Nigam, Agra